


Test Verification of Conformity

On the basis of the referenced test report(s), sample(s) of the below product have been found to comply with the harmonized standards and Directives listed on this verification at the time the tests were carried out. Other standards and Directives may be relevant to the product.

Once all product relevant  mark directives are verified in compliance, the manufacturer may indicate compliance by signing a Declaration of Conformity themselves and applying the mark to product identical to the test sample(s) if the product complies with all relevant CE mark Directives requirements.

Applicant Name & Address : Hangzhou Hanlight Electrical Co., Ltd.
 No.1228 West Park Road, Fuyang City, Zhejiang Province. P.R. China.

Manufacturing site Name & Address : Same as applicant

Product(s) Tested : Flush-type switch for fixed installation

Ratings and principal characteristics : 20A 250V~

Model(s) : V3240, V325, FC3240, MC3240, EF-P3240, EP-P3240, EC-P3240, FF-P3240, FT-P3240, DE-P3240, RA-P3240, MC-P3240, BH-P3240, BV-P3240, BC-P3240, BE-P3240, FF-U3240, FT-U3240, DE-U3240, RA-U3240, BH-U3240, BV-U3240, BC-U3240, BE-U3240
 V3241, V324, FC3241, MC3241, EF-P3241, EP-P3241, EC-P3241, FF-P3241, FT-P3241, DE-P3241, RA-P3241, MC-P3241, BH-P3241, BV-P3241, BC-P3241, BE-P3241, FF-U3241, FT-U3241, DE-U3241, RA-U3241, BH-U3241, BV-U3241, BC-U3241, BE-U3241
 WS3250, FC3250, MC3250, EF-P3250, EP-P3250, EC-P3250, FF-P3250, FT-P3250, DE-P3250, RA-P3250, MC-P3250, BH-P3250, BV-P3250, BC-P3250, BE-P3250, FF-U3250, FT-U3250, DE-U3250, RA-U3250, BH-U3250, BV-U3250, BC-U3250, BE-U3250
 WS3251, FC3251, MC3251, EF-P3251, EP-P3251, EC-P3251, FF-P3251, FT-P3251, DE-P3251, RA-P3251, MC-P3251, BH-P3251, BV-P3251, BC-P3251, BE-P3251, FF-U3251, FT-U3251, DE-U3251, RA-U3251, BH-U3251, BV-U3251, BC-U3251, BE-U3251

Brand name : Hanlight

Relevant Standard(s) / Specification(s) / Directive(s) : EN 60669-1:1999 + A1:2002 + A2:2008
 The Low Voltage Directive 2006/95/EC



Verification Issuing Office Name & Address : Intertek Testing Services Shanghai
 Building No.86, 1198 Qinzhou Road (North), Shanghai 200233, China

Verification Number : 141200087SHA-V1

Report Number(s) : 141200087SHA-001

NOTE 1: This verification is part of the full test report(s) and should be read in conjunction with it.

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

Oliver Wei
 Manager
 January 19, 2015